

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

29-3E 20F



WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission ("x" in circle) 183644

Construction
 Decommission ORIGINAL INSTALLATION Notice of Intent Number _____

PROPOSED USE: Domestic Industrial Municipal
 DeWater Irrigation Test Well Other _____

TYPE OF WORK: Owner's number of well (if more than one) _____
 New well Reconditioned Method: Dug Bored Driven
 Deepened Cable Rotary Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 215 ft.
 Depth of completed well 215 ft.

CONSTRUCTION DETAILS
 Casing Welded 6" Diam. from +1.5 ft. to 210 ft.
 Installed: Liner installed _____" Diam. from _____ ft. to _____ ft.
 Threaded _____" Diam. from _____ ft. to _____ ft.

Perforations: Yes No
 Type of perforator used _____
 SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.

Screens: Yes No K-Pac Location 209
 Manufacturer's Name Johnson
 Type _____ Model No. _____
 Diam. _____ Slot size _____ from _____ ft. to _____ ft.
 Diam. 6 Slot size 12 from 210 ft. to 215 ft.

Gravel/Filter packed: Yes No Size of gravel/sand _____ ft.
 Materials placed from _____ ft. to _____ ft.

Surface Seal: Yes No To what depth? 18 ft.
 Material used in seal Bentonite
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

PUMP: Manufacturer's Name _____ H.P. _____
 Type: _____

WATER LEVELS: Land-surface elevation above mean sea level 200+ ft.
 Static level 191 ft. below top of well Date 10/10/05
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)
 Time Water Level Time Water Level Time Water Level
 _____ _____ _____ _____ _____ _____
 Date of test _____
 Bailer test 10 gal./min. with no ft. drawdown after 1 hrs.
 Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

CURRENT
 Notice of Intent No. W178900
 Unique Ecology Well ID Tag No. ALT 044
 Water Right Permit No. _____
 Property Owner Name Verlane Gabelein
 Well Street Address Countner Ct
 City Clinton County Island
 Location SE 1/4-1/4 NW 1/4 Sec 20 Twn 29 R 3 EWM or WWM circle one
 Lat/Long (s, t, r) Lat Deg _____ Lat Min/Sec _____
 Still **REQUIRED** Long Deg _____ Long Min/Sec _____
 Tax Parcel No. _____

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

| MATERIAL | FROM | TO |
|---------------|------|-----|
| Brown sand | 0 | 2 |
| Sandy Hardpan | 2 | 14 |
| Clay Gray | 14 | 33 |
| Silty Sand | 33 | 74 |
| Sand Hardpan | 74 | 112 |
| Silty Sand | 112 | 170 |
| Brown Sand | 170 | 190 |
| Water sand | 190 | 215 |
| Blew sand | 211 | |
| More sand | 215 | |

Well site meets all set Backs under ICC 809 with restrictive cov Recorded with Island County Recorded on Sept 29 414 91 58

RECEIVED
 NOV 01 2005
 DEPT OF ECOLOGY

Start Date 10-3-05 Completed Date 10-10-05

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

Driller Engineer Trainee Name (Print) E Boonstra
 Driller/Engineer/Trainee Signature [Signature]
 Driller or trainee License No. 0038

Drilling Company WHIDBEY WELL DRILLERS
 Address 716 Holbrook Rd
 City, State, Zip Coupeville Wa 98239
 Contractor's Registration No. WHIDBWD97ILT Date 10-11-05

IF TRAINEE,
 Driller's Licensed No. _____
 Driller's Signature _____

Ecology is an Equal Opportunity Employer.